

## DISTRICT LEVEL LABORATORY, RWS&S DIVISION, BARGARH

The water quality report of one no of water sample collected & submitted by  
by the Principal , Cement nagar English Medium School , Bargarh is mentioned below.

Testing Date: - 05.02.2024

Sl No	Chloride in mg/ltr	Hardness in mg/ltr	Iron in mg/ltr	Fluoride in mg/ltr	PH in range	TDS in mg/ltr	Alkalinity in mg/ltr	Turbidity In NTU	Total Coliform	E-Coli
	Permissible limit 1000 mg/ltr	Permissible limit 600 mg/ltr	Permissible limit 1.0 mg/ltr	Permissible limit 1.5 mg/ltr	6.5 - 8.5	Permissible limit 2000 mg/ltr	Permissible limit 600 mg/ltr	Permissible limit 5 NTU	Permissible limit 00 Number	Permissible limit 00 Number
1	64 mg/ltr	224 mg/ltr	0.15 mg/ltr	0.53 mg/ltr	7.11	338 mg/ltr	236 mg/ltr	1.1	00	00

  
Jr. Lab Assistant  
RWS&S Division, Bargarh